



2121 Newmarket Pkwy
Suite 114
Marietta, GA 30067

ABC Company
180 New Boston Street
Woburn, MA 01801

Lab No: 9577
Logged Date: 06/18/01
Sample Drawn:
Report Date: 06/19/01
Ref. #: 708149

Unit ID:	Chiller #1	Mfg.	Carrier
Sample ID:	REFRIGERANT R-11	Model:	19C
Worksite:	ABC Bldg.	PO	
Time on Fluid:		Time on System:	

TESTING PERFORMED

REQUIREMENTS FOR: REFRIGERANT R-11

	Measured	Min	Max
Acidity, ppm (As HC1)	< 1		3
Water Content KF - D1744, ppm	276		
Oil Content - % Vol	0.47		5
Sediment, ppm	1		50
Appearance (Visual) of Refrigerant	Clear		
Color (Visual) of Refrigerant	Clear		

RECOMMENDATIONS / COMMENTS:

ANALYSIS INDICATES ABNORMAL CONDITIONS! WATER content is HIGH! CHECK for source of contaminant entry. Sample state, source and temperature not provided. IF SAMPLE IS CONDENSED VAPOR THE WATER CONTENT IS ACCEPTABLE.

Respectfully Submitted,

David A. James
Vice President, Technical Operations